



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **T S E**

BELGE NUMARASI <i>REFERENCE NUMBER OF LICENCE</i>	042472-TSE-01/06
BELGENİN İLK VERİLİŞ TARİHİ <i>DATE OF FIRST ISSUE OF LICENCE</i>	25.09.2012
BELGENİN SON GEÇERLİLİK TARİHİ <i>LICENCE VALID UNTIL</i>	06.09.2024
BELGE SAHİBİ KURULUŞUN ADI <i>NAME OF THE LICENCE HOLDER</i>	GEN ELEKTROMEKANİK SANAYİ VE TİCARET ANONİM ŞİRKETİ
BELGE SAHİBİ KURULUŞUN ADRESİ <i>ADDRESS OF THE LICENCE HOLDER</i>	EMEK MAH. ORDU CAD. NO:6 SANCAKTEPE İSTANBUL/TÜRKİYE
ÜRETİM YERİ ADI <i>NAME OF THE MANUFACTURING PLACE</i>	GEN ELEKTROMEKANİK SANAYİ VE TİCARET A.Ş.
ÜRETİM YERİ ADRESİ <i>ADDRESS OF THE MANUFACTURING PLACE</i>	EMEK MAHALLESİ ORDU CADDESİ NO:6/1 SANCAKTEPE İSTANBUL / TÜRKİYE
İPTAL EDİLEN BELGE NUMARASI (Varsa) <i>INDICATION OF SUPERSEDED LICENCE (if any)</i>	042472-TSE-01/05
TESCİLLİ TİCARİ MARKASI <i>REGISTERED TRADE MARK</i>	"genemek marka +şekil ibareli"
İLGİLİ TÜRK STANDARDI <i>RELATED TURKISH STANDARD</i>	TS EN 60947-5-1 / 19.03.2018

BELGE KAPSAMI
SCOPE OF LICENCE

CIRCUIT CONTROL DEVICES AND SWITCHING ELEMENTS – ELECTROMECHANICAL CONTROL CIRCUITS DEVICES
TYPE: PUSH TYPE, CIRCUIT BREAKING CONTROL DEVICE
MODEL: AVOX, QUAD
RATED OPERATING VOLTAGE AND FREQUENCY: 24V DC
DECLARED INSULATION VOLTAGE (UI): 60V
PROTECTION RATING: IP 20
IMPULSE WITHSTAND VOLTAGE (Uimp): 2,5 Kv
USAGE CATEGORY: DC 12
RATED CURRENT (Ie): 0,1 A

CIRCUIT CONTROL DEVICES AND SWITCHING ELEMENTS – ELECTROMECHANICAL CONTROL CIRCUITS DEVICES

(042472-TSE-01/06nolu belge devamı) : GEN ELEKTROMEKANİK SANAYİ VE TİCARET ANONİM ŞİRKETİ
İLGİLİ TÜRK STANDARDI(RELATED TURKISH STANDARD) TS EN 60947-5-1 / 19.03.2018

TYPE: PUSH TYPE, CIRCUIT BREAKING CONTROL DEVICE
MODEL: RADIAN
RATED OPERATING VOLTAGE AND FREQUENCY: 24V DC
DECLARED INSULATION VOLTAGE (UI): 60V
PROTECTION RATING: IP 20
IMPULSE WITHSTAND VOLTAGE (Uimp): 2,5 Kv
USAGE CATEGORY: DC 12
RATED CURRENT (Ie): 0,1 A

e-imzalı/e-signed

18.10.2023

On Behalf Of The Head Of Certification Center
AKDOĞAN BULUT

MANAGER OF THE TSE ISTANBUL
CERTIFICATION DEPT. P.

*This certificate also shows that the production place of the certified product meets the requirements of Institute.

*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.

*TSE * Address: Çayırova Tren İstasyonu Yanı ÇAYIROVA/GEBZE * Telephone: 2627231273* Fax: 2627231606

*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail

:bmb@tse.org.tr , web : www.tse.org.tr

